

Our Ref: HL/M1203046
Test Report: MA4604/B



8th November 2012

Plascoat Systems Ltd.
Farnham Trading Estate,
Farnham,
Surrey,
GU9 9NY

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FACTORY APPLIED PIPE & FITTING COATINGS

5030

PPA 571 Aqua. Factory applied, blue coloured, polyolefin coating. Apply and cure as per manufacturer's instructions. For use with water up to 23°C.

APPROVAL NUMBER: 1210531
APPROVAL HOLDER: PLASCOAT SYSTEMS LTD.

The Scheme reserves the right to review approval. This approval is valid between October 2012 and October 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', is written over a light blue circular watermark.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme

Water Regulations Advisory Scheme Ltd.
30 Fern Close, Pen-y-Fan Industrial Estate,
Oakdale, Gwent NP11 3EH, UK.
Tel: 01495 248454. Fax: 01495 236289.
E-mail: info@wras.co.uk Website: www.wras.co.uk

The Water Regulations Advisory Scheme Ltd
Registered in England No. 05661930
Registered Office: 1 Queen Anne's Gate,
London SW1H 9BT